

## **Media Life Analysis Test Report**

<b>CLIENT:</b>	City of Laredo Utilities	<b>REPORT DATE:</b>	5/1/2023
<b>PLANT/MILL SITE:</b>	South Plant WWTF	<b>SAMPLE DATE:</b>	4/18/2023
<b>TECHNICIAN:</b>	Julz	<b>MEDIA REPLACEMENT DATE:</b>	ASAP

<b><u>SAMPLE #:</u></b>	<b><u>AREA:</u></b>	<b><u>DESCRIPTION / NOTES:</u></b>	<b><u>MEDIA TYPE:</u></b>	<b><u>RESULTS (% LIFE REMAINING):</u></b>
1	Top Port	1 Ton EGS	Safetysorb	38%
2	Middle Port	1 Ton EGS	Safetysorb	44%
3	Bottom Port	1 Ton EGS	Safetysorb	42%